

1 AN ACT concerning education.

2 **Be it enacted by the People of the State of Illinois,**  
3 **represented in the General Assembly:**

4 Section 5. The Fire Sprinkler Dormitory Act is amended by  
5 changing Section 10 as follows:

6 (110 ILCS 47/10)

7 Sec. 10. Fire sprinkler systems required. Subject to the  
8 establishment of a fire sprinkler dormitory revolving loan  
9 program under Section 15 of this Act, fire sprinkler systems  
10 are required in the dormitories of all post-secondary  
11 educational institutions by 2013, unless a post-secondary  
12 educational institution files a compliance plan with the Office  
13 of the State Fire Marshal, approved by the Office by January 1,  
14 2013. The compliance plan must be submitted no later than  
15 November 1, 2012 and must include all of the following:

16 (1) Fire sprinkler system working drawings and  
17 hydraulic calculations.

18 (2) A water supply analysis to determine available  
19 water and the need for a fire pump.

20 (3) A fire sprinkler system installation schedule  
21 showing a minimum of the following:

22 (A) the drawing and calculation submittal date to  
23 the authority having jurisdiction and the projected

1 duration;

2 (B) the fabrication and material procurement date  
3 and the projected duration;

4 (C) the field installation start date and the  
5 projected duration;

6 (D) the final testing and punch list date and the  
7 projected duration; and

8 (E) the projected project completion date.

9 If the compliance plan is approved by the Office of the State  
10 Fire Marshal, then the deadline for fire sprinklers to be  
11 installed and operational shall be extended to September 1,  
12 2014. A violation of this Section is a business offense  
13 punishable by a fine of not more than \$1,000 per day. This fire  
14 sprinkler system requirement includes current structures as  
15 well as newly constructed dormitories. Nothing in this Act may  
16 be construed to abrogate any statute, rule, or ordinance  
17 requiring that a fire extinguisher be present in a dormitory.

18 (Source: P.A. 93-887, eff. 1-1-05; 94-204, eff. 7-14-05.)