92_HB3647 LRB9210073ACcdA

- 1 AN ACT concerning swimming facilities.
- 2 Be it enacted by the People of the State of Illinois,
- 3 represented in the General Assembly:
- 4 Section 5. The Swimming Facility Act is amended by
- 5 changing Section 9 and adding Section 9.1 as follows:
- 6 (210 ILCS 125/9) (from Ch. 111 1/2, par. 1209)
- 7 Sec. 9. Inspections; written notice. Subject to
- 8 constitutional limitations, the Department, by its
- 9 representatives, after proper identification, is authorized
- 10 and shall have the power to enter at reasonable times upon
- 11 private or public property for the purpose of inspecting and
- 12 investigating conditions relating to the enforcement of this
- 13 Act and regulations issued hereunder. The Department must
- 14 <u>inspect all electrical systems and fixtures associated with a</u>
- 15 <u>swimming pool before an original license or a renewal of a</u>
- license for the swimming pool may be issued under this Act.
- 17 Written notice of all violations shall be given to the
- owners, operators and licensees of swimming facilities.
- 19 (Source: P.A. 92-18, eff. 6-28-01.)
- 20 (210 ILCS 125/9.1 new)
- 21 <u>Sec. 9.1. Underwater lighting systems.</u>
- 22 (a) All underwater lighting systems operating at more
- 23 <u>than 15 volts supplied from a branch circuit either directly</u>
- 24 <u>or by way of a transformer must be designed and installed in</u>
- 25 <u>a swimming pool so that there is no shock hazard with any</u>
- 26 <u>likely combination of fault conditions during normal use, and</u>
- 27 <u>must comply with the requirements of this Section.</u>
- 28 (b) An approved ground-fault circuit interrupter must be
- 29 <u>installed</u> in the branch circuit that supplies all fixtures
- 30 <u>operating at more than 15 volts.</u>

1	(c) Only underwater	lighting	fixtures	approved	by	<u>the</u>
2	Department may be used.					

- 3 (d) No lighting fixtures may be installed for operation
 4 at more than 150 volts between conductors.
- (e) Any swimming pool that does not meet the requirements specified in this Section shall be retrofitted to comply with the requirements of this Section within 120
- 8 days after the effective date of this amendatory Act.